

## PL Alarms

### PL20/40

Wire alarm/buzzer between Battery positive and "G", or "Load-" terminal.

NOTE: Max 'G' terminal current = 120mA

### PL60

If using the 'G' Terminals; wire alarm/buzzer between Battery Positive and Battery Negative with the two 'G Contact' terminals in series like a switch.

(NOTE: Max "G Contact" terminal current = 300mA)

...or...

If using the LOAD Terminals; wire alarm/buzzer between LOAD POS and LOAD NEG.

### **Voltage Triggered Alarm:**

Configure 'GSET' if using 'G' Terminals.

Configure 'LSET' if using 'LOAD-' or LOAD Terminals.

SET -> MODE -> LSET=9 (alarm output on when battery voltage < ALRM setting)  
Or GSET=9 (alarm output on when battery voltage < ALRM setting)

SET -> MODE -> ALRM=11.4V (this default value can be changed)

### **State Of Charge (SOC) Triggered Alarm:**

You must monitor all charge and load current so that SOC number is correct at all times.

SET -> MODE -> LSET=2 (on when function wants to turn on Alarm)  
Or GSET=2 (on when function wants to turn on Alarm)

CHRG -> CINT -> GSET -> GMOD=6 (SOC% driven with no quite time)

CHRG -> CINT -> GSET -> GMOD -> GON=??% (SOC% at which alarm turns ON)

CHRG -> CINT -> GSET -> GMOD -> GOFF=??% (SOC% at which alarm turns OFF)

CHRG -> CINT -> GSET -> GMOD -> GRUN=0 (otherwise generator exercise causes alarm)

See 'PL Reference Manual' for other Generator control functions and options (in this case used for Alarms).